



SAFETY DATA SHEET MagneGas[®]

Rev. H

SECTION 1: IDENTIFICATION

Product Identifier: MagneGas[®], MG1, M1

Recommended Use: A flammable gaseous fuel

Company Details: MagneGas Corporation
150 Rainville Road
Tarpon Springs, FL 34689
Tel No: 727 934-3448
FAX No: 727 934-6260
Email: Info@magnegas.com
Website: <http://www.magnegas.com>

Emergency Phone: For Chemical Emergency Spill, Leak, Fire, Exposure, or Accident Call CHEMTREC Day or Night
Within USA and Canada: 1-800-424-9300
Outside USA and Canada: +1 703-527-3887 (Collect calls accepted)

SECTION 2: HAZARD IDENTIFICATION

Classification of MagneGas[®]

GHS Classification: Flammable Gas – 1
Compressed Gas
Acute Toxicity, Inhalation – 4
Skin Corrosion / Irritation – 3
Serious Eye Damage / Eye Irritation – 2B

GHS Label Elements

Pictograms:



Flame



Gas Cylinder



Exclamation Mark

Signal Word: Danger

Hazard Statements:	Code	Description
	H220	Extremely Flammable Gas
	H280	Contains gas under pressure; may explode if heated
	H316	Causes mild skin irritation
	H320	Causes eye irritation
	H332	Harmful if inhaled

Precautionary Statements:	Code	Description
	P202	Do not handle until all safety precautions have been read and understood
	P210	Keep away from heat/sparks/open flames/hot surfaces. - No smoking.
	P261	Avoid breathing gas.
	P264	Wash thoroughly after handling
	P271	Use only outdoors or in well ventilated area.
	P280	Wear protective clothing, protective gloves, eye protection, face protection
	P377	Leaking gas fire: Do not extinguish, unless leak can be stopped safely
	P381	Eliminate all ignition sources if safe to do so
	P403	Store in a well ventilated area.
	CGA-PG02	Protect from sunlight when ambient temperature exceeds 52°C (125°F).
	CGA-PG05	Use a back flow preventive device in the piping.
	CGA-PG06	Close valve after each use and when empty.
	CGA-PG10	Use only with equipment rated for cylinder pressure.
	CGA-PG12	Do not open valve until connected to equipment prepared for use.

Other Hazards: May cause asphyxia.
May cause frostbite upon sudden release of compressed gas.



SAFETY DATA SHEET

MagneGas[®]

Rev. H

SECTION 3: COMPOSITION / INFORMATION ON INGREDIENTS

Component Name	CAS#	% (Vol/Vol)
Hydrogen	1333-74-0	55 – 65%
Carbon Monoxide	630-08-0	30 – 35%
Carbon Dioxide	124-38-9	1 – 2 %
Trace Gases	NA	0.5 – 1 %

SECTION 4: FIRST AID MEASURES

- Inhalation:** Remove person to fresh air and keep comfortable for breathing. Give artificial respiration if not breathing. If breathing is difficult, oxygen should be administered by qualified personnel. Get immediate medical attention.
- Skin Exposure:** Wash exposed skin with soap and water. If skin irritation occurs, get medical attention. If frostbite or freezing occur, immediately flush with plenty of lukewarm water (105-115 F°; 41-46° C). DO NOT USE HOT WATER. If warm water is not available, gently wrap affected parts in blankets. Get immediate medical attention.
- Eyes Exposure:** Rinse cautiously with water for several minutes. Remove contact lenses if present and easy to do. Continue rinsing and flush eyes with plenty of water for at least 15 minutes. Call a doctor/physician if eye irritation persists.
- Ingestion:** MagneGas[®] is a gas at normal temperature and pressure, ingestion is an unlikely method of exposure.
- Note to physicians:** For inhalation, consider oxygen.
- Symptoms – Immediate:** Frostbite or burns due to expanding gases
Suffocation
- Symptoms – Delayed:** No information on significant adverse effects.

SECTION 5: FIRE-FIGHTING MEASURES

- Suitable Extinguishing Media:** Carbon dioxide, regular dry chemical, water, halon.
- Unsuitable Extinguishing Media:** None known.
- Specific Hazards Arising from Substance or Mixture**
- Fire Hazard:** Extremely flammable gas. Electrostatic discharges may be generated by flow or agitation resulting in ignition or explosion.
- Explosion Hazard:** Cylinders contain gas under pressure, gas/air mixture is explosive. Pressurized containers may rupture and/or explode if exposed to sufficient heat. Electrostatic discharges may be generated by flow or agitation resulting in ignition or explosion.
- Fire Fighting Measures:** Evacuate all personnel from the danger area, keep all unnecessary people away, isolate hazardous area and deny entry. In the case of high risk event let burn and evacuate area to safe distance.
- Move cylinders from fire area if it can be done safely and without risk. Use water spray to keep cylinder and/or other containers cool if exposed to fire. Continue to cool containers with water spray until well after the fire is out. Withdraw immediately in case of rising sound from venting safety device or any discoloration of tanks due to fire.
- For tank, rail car or tank truck: Stop leak if possible without personal risk. Let burn if leak cannot be stopped immediately. Do not attempt to extinguish fire unless flow of material can be stopped first. Flood with fine water spray. Cool containers with water spray until well after the fire is out. Apply water from a protected location or from a safe distance.



SAFETY DATA SHEET MagneGas[®]

Rev. H

Avoid inhalation of product or by-products. Stay upwind and keep out of low areas.

MagneGas[®] is lighter than air and will disperse rapidly in an open environment. Gas may pool at the roof peak in unventilated areas. Burned MagneGas[®] releases a high percentage of oxygen.

Protective Equipment and Precautions for Firefighters:

Wear full protective firefighting gear including self-contained breathing apparatus (SCBA) for protection against possible exposure.

SECTION 6: ACCIDENTAL RELEASE MEASURES

- General:** Forms an explosive mixture with air. Immediately evacuate all personnel from the risk area.
- MagneGas[®] is lighter than air and will disperse rapidly in an open environment. However gas may pool at the roof peak in unventilated areas. Shut off gas flow and ventilate area using explosion-proof equipment and methods if it safe to do so.
- Personal Precautions:** Wear personal protective clothing and equipment.
- Environmental Precautions:** Avoid release to the environment.
- Methods for Containment:** Keep unnecessary people away, isolate hazard area and deny entry. Remove sources of ignition if it can be done without risk. Ventilate closed spaces before entering.
- Cleanup Methods:** Avoid heat, flames, sparks and other sources of ignition at all times.
Leaking gas fire: Do not extinguish, unless leak can be stopped quickly and safely without personal risk.

SECTION 7: HANDLING AND STORAGE

Precautions for Safe Handling:

- Cylinders:** Keep away from heat/sparks/open flames/hot surfaces. - No smoking. Use only non-sparking tools and explosion proof equipment. Always protect cylinders and valves from physical damage, do not puncture. Do not pick up cylinders by cap or valve. Always move cylinders with the proper equipment. Empty cylinders retain residual material and can be hazardous. Keep containers closed when not in use. Containers even those that have been emptied, can contain explosive vapors. Do not cut, drill, grind, weld or perform similar operations around or near cylinders or containers.
- Personnel:** Wear the appropriate protective clothing and equipment (steel toe shoes, safety gloves, protective eye wear, face shields, and breathing apparatuses) when handling cylinders and gas.
- Equipment:** Only use equipment rated for the maximum cylinder pressure and compatible with gas elements.
- Storage:** Store in accordance with local regulations. Store in a dry and well-ventilated place. Remove all sources of ignition in the storage area and keep away from open flames and high temperatures. Keep separated from incompatible substances. Use explosion-proof ventilation system to prevent vapor accumulation. Cylinders should always be transported and stored in an upright position and properly secured. Cylinder temperature should never exceed 50°C (125°F).



SAFETY DATA SHEET

MagneGas[®]

Rev. H

SECTION 8: EXPOSURE CONTROLS/PERSONAL PROTECTION

COMPONENT EXPOSURE LIMITS

Component Name:	CAS#	% (Vol/Vol)	OSHA PEL-TLV (ppm; mg/m3)	ACGIH TLV-TWA (ppm; mg/m3)
Hydrogen	1333-74-0	55 – 65%	None	Simple Asphyxiant
Carbon Monoxide	630-08-0	30 – 35%	50; 55	25
Carbon Dioxide	124-38-9	1 – 2 %	5,000; 9,000	5,000; 9,000
Trace Gases	NA	0.5 – 1 %		

- Engineering Controls:** Ventilation equipment should be explosion-resistant if explosive concentrations of material are present. Provide local exhaust ventilation system. Ensure compliance with applicable exposure limits and local regulations.
- Hand Protection:** Wear working gloves when handling cylinders. Welders' gloves are required for cutting operations.
- Eye/Face Protection:** Wear safety glasses with side shields when working with cylinders. Wear protective face shields or vapor-proof goggles when changing out cylinders or working closely with gas in cutting, manufacturing, and/or combustion applications. Welders' goggles or similar equipment are required for cutting and welding operations. Select in accordance with OSHA 29 CFR 1910.133.
- Skin Protection:** Always wear the proper skin protection based on the task being performed. Leather sleeves, leather apron, and other standard protective equipment are required for cutting. Select in accordance with OSHA 29 CFR 1910.132 and 1910.133.
- Respiratory Protection:** Respiratory equipment must be worn when servicing the cylinders. Equipment selection must be based on anticipated exposure levels. Respiratory equipment must be properly fitted for the personnel performing the task. For use within a confined space, refer to 29 CFR 1910.146
- Foot Protection:** Always wear steel-toed work shoes/boots when moving cylinders.
- General Hygiene:** Thoroughly wash hands, fore-arms, and face after handling the product and prior to eating, smoking, and/or using restrooms.

SECTION 9: PHYSICAL AND CHEMICAL PROPERTIES

PHYSICAL STATE:	Gas	APPEARANCE:	Colorless Gas
COLOR:	Colorless	PHYSICAL FORM:	Gas
ODOR:	Distinct Hydrocarbon odor	ODOR THRESHOLD:	Not Available
TASTE:	Tasteless	MELTING/FREEZING POINT:	Not Available
BOILING POINT:	Not Available	FLASH POINT:	0°F / -18°C - Cleveland closed cup
DECOMPOSITION:	Not Available	EVAPORATION RATE:	Not Available
LEL:	7.6%	UEL:	63.4%
VAPOR PRESSURE:	Not Available	VAPOR DENSITY (AIR=1):	Not Available
DENSITY:	0.0259 lb/ft ³	SPECIFIC GRAVITY:	0.3387 (Compared to dry normal air)
LOG KOW:	Not Available	WATER SOLUBILITY:	Not Available
AUTO IGNITION:	932°F / 500°C	COEFF. WATER.OIL DIST.	Not Available
MOLECULAR WEIGHT:	9.81	VISCOSITY:	Not Available
pH:	Not Available	pH (Other):	Not Available
PERCENT VOLATILE:	100%	VOLATILE ORGANIC COMPOUNDS:	Not Available



SAFETY DATA SHEET MagneGas[®]

Rev. H

SECTION 10: STABILITY AND REACTIVITY

Reactivity:	No specific data available.
Chemical Stability:	Stable at normal temperatures and pressure.
Possibility of Hazardous Reactions:	Will not polymerize.
Conditions to Avoid:	Storage in excess of 2,500 scf should be outdoors or in well-ventilated area. Avoid heat, flames, sparks and other sources of ignition. Minimize contact with material. Containers may rupture or explode if exposed to heat.
Incompatible Materials:	Oxidizing Lithium, Halogens
Hazardous Decomposition Products:	None under normal combustion conditions.

SECTION 11: TOXICOLOGICAL INFORMATION

Acute Toxicity:	Not available.
Irritation/Corrosion:	Not available.
Sensitization:	Not available.
Mutagenicity:	Not available.
Carcinogenicity:	Not available.
Reproductive Toxicity:	Not available.
Specific Target Organ Toxicity (single exposure):	Not available.
Specific Target Organ Toxicity (repeated exposure):	Not available.
Aspiration Hazard:	Not available.

SECTION 12: ECOLOGICAL INFORMATION

Toxicity:	Not available.
Persistence and Degradability:	Not available.
Bio accumulative Potential:	Not available.
Mobility in Soil:	Not available.
Other Adverse Effects:	None known.

SECTION 13: DISPOSAL CONSIDERATIONS

Disposal Methods:	Waste should be avoided or minimized at all times. Disposal of this product and any by-products must comply with local, regional, and national level requirements. Any non-recyclable waste material should always be disposed of via a licensed waste disposal provider. Return empty or unused MagneGas [®] cylinders to MagneGas Corporation.
--------------------------	--



SAFETY DATA SHEET MagneGas[®]

Rev. H

SECTION 14: TRANSPORT INFORMATION

U.S. Department of Transportation (DOT)

UN Number: UN1954

UN Proper Shipping Name: COMPRESSED GAS, FLAMMABLE, N.O.S. (CONTAINS MAGNEGAS, 55 - 65% Hydrogen)

Hazard Class: 2.1 – Class 2.1 – Flammable gas



Special Transport Precautions:

Cylinders should be transported in a secure position, in a well-ventilated vehicle. Cylinders transported in an enclosed, non-ventilated compartment of a vehicle can present serious safety hazards. Ensure personnel transporting product is aware of all danger and what to do in case of an accident or emergency.

Other Information: Shipment of compressed gas cylinders that have been filled without the owner's consent is a violation of federal law [49 CFR 173.301(b)].

SECTION 15: REGULATORY INFORMATION

U.S. Federal Regulations: None of this products components are listed under SARA Sections 302/304 (40 CFR 355 Appendix A), SARA Section 311/312 (40 CFR 370.21), SARA Section 313 (40 CFR 372.65), CERCLA (40 CFR 302.4), TSCA 12(b), or require an OSHA process safety plan.

SARA 311/312 Hazardous Categories:

Immediate Acute Health: Yes

Chronic Health: No

Fire Hazard: Yes

Pressure Hazard: Yes

Reactive: No

SARA 313 Reportable Ingredients:

Requires submission of annual reports of release of toxic chemicals that appear in 40 CFR Part 372, not listed.

TSCA (Toxic Substance Control Act):

Not Applicable.

CERCLA (Comprehensive Response Compensation, and Liability Act):

Not Applicable.

U.S. State Regulations: The following components appear on one or more of the following state hazardous substances lists:

Component	CAS#	CA	MA	MN	NJ	PA	RI
Hydrogen	1333-74-0	Yes	Yes	Yes	Yes	Yes	Yes
Carbon Monoxide	630-08-0	Yes	Yes	Yes	Yes	Yes	Yes
Carbon Dioxide	124-38-9	Yes	Yes	Yes	Yes	Yes	Yes



SAFETY DATA SHEET
MagneGas[®]

Rev. H

SECTION 16: OTHER INFORMATION

Revision History:

Date	Description	Revision
3/9/2011	Initial MSDS release	1 (A)
9/17/2013	Chemical make-up updated	7 (G)
3/26/2015	SDS format update	H

All revisions are controlled by the MagneGas Corporation. The latest revision of the SDS can be downloaded from the following MagneGas website: <http://magnegas.com/brochures/>.

Information contained in this document is based on present knowledge of the product. MagneGas, its subsidiaries, and distributors assume no liability for the accuracy and completeness of this document and the information contained within. All products and their components may have inherent unknow hazards and should always be used with caution. This document describes certain known hazards, however, MagneGas cannot guarantee that these are the only hazards. Product suitability, applicability, and safe use is the sole responsibility of the user.